

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1335:109 Page 1 of 1

CATEGORY: Power Units

LISTEE: Altronix Corp., 140 - 58th Street, Building A-3W, Brooklyn NY 11220
Contact: Bob Scanapico (718) 567-8181 Fax (718) 567-9056

DESIGN: Models AL642UL-ADA, AL842UL-ADA, and AL1042UL-ADA Indicating Circuit Power Supply. Unit is a regulated 12 or 24 VDC power supply/charger used for supervision and expanded power driving capability of four notification appliance circuits. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 VAC primary, 12 or 24 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: The system must have the secondary power supply capable of operating the system for at least 24 hours battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required by code. The battery circuit must be fully supervised.

08-04-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**